

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

EFFECTIVE THURSDAY NOVEMBER 13, 2008 DRINKING WATER PROBLEM CORRECTED

Donner Summit PUD Water System

It is no longer necessary to boil your tap water
or to consume bottled water.

As customers of the Donner Summit PUD (DSPUD) Water System, you were notified on October 31, 2008, of a problem with our drinking water and were advised to use boiled or bottled water for domestic purposes. DSPUD is pleased to report that the problem has been corrected and that it is no longer necessary to use boiled or bottled water.

The problem was determined to be the filter media at the water treatment plant that has now been replaced. The treatment plant has been returned to service and it is producing water that meets state water quality standards.

The distribution system has been thoroughly flushed. The State of California Department of Public Health in conjunction with DSPUD has determined that, based on water monitoring and water quality test results, the system water is safe to drink.

As always, you may contact DSPUD at 426-3456 or the State of California Department of Public Health at (530) 224-4800 with any comments or questions.

Please share this information with all the other people who may drink this water, especially those who may not have received this notice directly (for example, people in condominiums, apartments, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

We apologize for the inconvenience and we thank you for your patience. This notice is being sent to you by the Donner Summit Public Utility District. State Water System ID#: 2910016